



NOTES:

1. PIPING DIAGRAM FOR HIGH TEMPERATURE STORAGE WITH A TEMPERATURE MAINTENANCE/TRIM TANK. FOR OTHER CONFIGURATIONS CONSULT YOUR LYNC REPRESENTATIVE.
2. THE TEMPERATURE & PRESSURE RELIEF VALVE SHOULD NOT EXCEED PRESSURE RATING OF ANY COMPONENT IN THE SYSTEM.
3. ALL DRAINS SHOULD BE ARRANGED TO PERMIT THE FLUIDS TO DRAIN FREELY, BY GRAVITY, TO A FLOOR DRAIN. RELIEF VALVE DISCHARGE SHOULD BE PIPED TO THE NEAREST FLOOR DRAIN. WHEN NO FLOOR DRAIN IS AVAILABLE, THE RELIEF VALVE DISCHARGE SHOULD BE PIPED VERTICALLY TO A HEIGHT OF AT LEAST 6"-12" ABOVE THE FLOOR.
4. SERVICE VALVES ARE SHOWN FOR SERVICING UNITS. HOWEVER, LOCAL CODES SHALL GOVERN THEIR USAGE.
5. **WARNING:** THE DRAWING SHOWS SUGGESTED PIPING CONFIGURATION AND OTHER DEVICES; CHECK WITH LOCAL CODES AND ORDINANCES FOR ADDITIONAL REQUIREMENTS.



Blauvelt, NY
Fort Worth, TX

MULTIPLE AEGIS HEAT PUMP WATER
HEATER WITH (1) STORAGE TANK AND
TRIM TANK

DWN.BY K.S. DATE 082521
SCALE NTS
REV.BY K.S. DATE 120321

SD-L-1233

REV.
B