



INSTRUMENT LEGENDS	
(TS) TEMPERATURE SENSOR	CIRCULATING PUMP
THERMOMETER	TEMPERATURE & PRESSURE RELIEF VALVE
BALL VALVE & HOSE BIBB	CHECK VALVE
BALL VALVE	STRAINER
UNION CONNECTION	MIXING VALVE

- NOTES:
1. PIPING DIAGRAM FOR HIGH TEMPERATURE STORAGE WITH A TEMPERATURE MAINTENANCE/SWING TANK. FOR OTHER CONFIGURATIONS CONSULT YOUR LYNC REPRESENTATIVE.
  2. THE TEMPERATURE & PRESSURE RELIEF VALVE SHOULD NOT EXCEED PRESSURE RATING OF ANY COMPONENT IN THE SYSTEM.
  3. ALL DRAINS SHOULD BE ARRANGED TO PERMIT THE FLUIDS TO DRAIN FREELY, BY GRAVITY, TO A FLOOR DRAIN. RELIEF VALVE DISCHARGE SHOULD BE PIPED TO THE NEAREST FLOOR DRAIN. WHEN NO FLOOR DRAIN IS AVAILABLE, THE RELIEF VALVE DISCHARGE SHOULD BE PIPED VERTICALLY TO A HEIGHT OF AT LEAST 6"-12" ABOVE THE FLOOR.
  4. SERVICE VALVES ARE SHOWN FOR SERVICING UNITS. HOWEVER, LOCAL CODES SHALL GOVERN THEIR USAGE.
  5. **WARNING:** THE DRAWING SHOWS SUGGESTED PIPING CONFIGURATION AND OTHER DEVICES; CHECK WITH LOCAL CODES AND ORDINANCES FOR ADDITIONAL REQUIREMENTS.

**Lync** by **Watts** Blauvelt, NY  
Fort Worth, TX

AEGIS HEAT PUMP WATER HEATER WITH  
(3) STORAGE TANK, MEDIUM TEMPERATURE

DWN. BY <u>K.S.</u> DATE <u>082820</u>	SD-L-1216	REV. B
SCALE <u>NTS</u>		
REV. BY <u>K.S.</u> DATE <u>010521</u>		