



Use RS485 port for:

- MODBUS RTU
- BACNet MSTP

Use the Ethernet port on the top of the controller for:

- MODBUS TCP
- BACNet IP.

A cable is supplied with the unit to the external connection.

Notes:
1) Connector provided at bottom of electrical enclosure.

- CAT5e / CAT6 as per BMS (BACNet IP)
- 18 AWG Twisted and Shielded Wire (150' max), 16 AWG (150' - 270') or 15 AWG 270' to 360')
- - - - - 24 AWG min

NOT FOR CONSTRUCTION

		Fort Worth, TX 76134 Blauvelt, NY 10913	
<h3>MII Seq. Low Voltage</h3>			
DRWN. BY	DATE	DWG. NO:	REV.
BJC	03/27/23	SD-L-1287	A
Page 2 of 46			