



NOT FOR CONSTRUCTION

- CAT5e / CAT6 as per BMS (BACNet IP)
- 18 AWG Twisted and Shielded Wire (150' max), 16 AWG (150' - 270') or 15 AWG (270' to 360')
- 24 AWG min

		Fort Worth, TX 76134 Blauvelt, NY 10913	
<h3>MII WS Sensors 3 Tank</h3>			
DRWN. BY	DATE	DWG. NO:	REV.
BJC	03/27/23	SD-L-1289	A
			Page 2 of 46