



Notes:  
 1) See sensor diagram for sensor locations.

- ..... CAT5e / CAT6 as per BMS (BACNet IP)
- 18 AWG Twisted and Shielded Wire (150' max), 16 AWG (150' - 270') or 15 AWG 270' to 360')
- . - . - . 24 AWG min

NOT FOR CONSTRUCTION

|          |          |  |          |
|----------|----------|--|----------|
|          |          | Fort Worth, TX 76134<br>Blauvelt, NY 10913 |          |
|          |          | <h3>Aegis Sequencer Wiring</h3>            |          |
| DRWN. BY | DATE     | DWG. NO:                                   | REV.     |
| BJC      | 03/28/22 | SD-L-1248                                  | <b>B</b> |
|          |          | Page 4 of 46                               |          |